52026

S D

52026

Street Number

370

Street Dir

S

Document Date

12/6/66

Street Name

WINCHESTER

Street Type

BL

Tract Number

Sub Doc Type

BL

Doc Type

PL

Box Number

	Prepped By	Scanned By	Indexed By	Verified By
Initials	Michelle W.			
Date	4/10/01			

CARL N. SWENSON CO., INC.
Contractors

777 NORTH FIRST STREET
SUITE 370
TELEPHONE 294-3232

ADDRESS ALL MAIL TO
P. O. BOX 558
SAN JOSE, CALIFORNIA 95106

[redacted]

December 23, 1966

City of San Jose
Building Department
Mission and North 1st Streets
San Jose, California

BEST AVAILABLE

Re: McDonnell and Company
San Jose, California

Gentlemen:

Enclosed is one (1) copy each of Hales Testing Laboratories Reports as follows:

Field Density Test, Lab. No. SJ-3611-S, dated December 20, 1966, and

HVEEM Stabilometer Test, Lab. No. SJ-3612-S, dated December 20, 1966,

on the above-referenced project.

We are forwarding one (1) copy each of these reports to our Job Superintendent and are keeping one (1) copy each for our records.

Very truly yours,

CARL N. SWENSON CO., INC.

William P. Ondrasek

WPO:ro
Encls.

cc: William A. Patrick (w/encls)
Job Office (w/encls)

52026-V

LABORATORY CERTIFICATE

[redacted]

SD

HALES TESTING LABORATORIES

TESTING & INSPECTION SERVICES
CHEMISTS · METALLURGISTS

LABORATORIES
OAKLAND
SAN JOSE
MONTEREY
SAN FRANCISCO

REPLY TO
1309 Terminal Avenue
San Jose, California
297-0874

P. O. #5683

December 20, 1966

BEST AVAILABLE

LAB NO: SJ 3612_s

PROJECT: MC DONNELL BUILDING
San Jose, California

MARK: Santa Clara Sand and Gravel

SAMPLE: Import Fill Material

DATE RECEIVED: December 15, 1966

DATE TESTED: December 20, 1966 TESTED BY: A. Lynch

REPORT TO: C. M. Swenson Company, Inc., Contractor
P. O. Box 558
San Jose, California 95106
Attention: Mr. William P. Ondrasek

REPORT
HVEEM STABILOMETER TESTS
(California Test Method No. 301-F)

Specimen No:	Exudation Pressure PsI	Per Cent Moisture	Expansion Pressure PSF	Density Lbs./Cu.Ft.	"R" Value
1	157	10.6	52	130.3	65
2	369	10.2	78	131.2	72
3	580	9.7	95	132.0	80
	300	10.3	69	130.9	70
	400	10.1	80	131.3	73

Respectfully submitted,

HALES TESTING LABORATORIES

By [signature]

HBLwll/ss

5 cc C. M. Swenson Company, Inc., Contractor
Attention: Mr. William P. Ondrasek

52026

INSPECTING, TESTING, ANALYSES OF CONSTRUCTIONAL AND INDUSTRIAL MATERIALS